


Fitting Instruction
Code:ym.06.06-00.01

A	B	C	D	E	HEAT OUTPUTS (BTU)	HEAT OUTPUTS (WATT)
HEIGHT mm	LENGTH mm	PIPE CENTER mm	VERTICAL BRACKET CENTERS mm	HORIZONTAL BRACKET CENTERS mm	Delta T:50°C	Delta T:50°C
636	300	50	420	150	1794	526
1066	300	50	850	150	3311	971
1506	300	50	1280	150	4839	1419



Bracket Assembly

